

DECLARATION OF PERFORMANCE
DoP No: 260982-01/06 AE3

Product type: JB-Y(St)Y Fire Alarm Cable

Name and contact address of the manufacturer: Alevado Energy Doo Str. Nenaseleno mesto bez ulichen system
Bashino Selo, 1400 Veles, North Macedonia
e-mail: alevadoenergy@gmail.com
www.alevadoenergy.com

Intended use: Mainly used for signaling and data transmission in fire detection and security systems. Specifically designed for fire alarm systems and signal transmission where electrostatic shielding is required. This cable is also suitable for fire alarm systems, for signal and data transmission.

Conformity to EU Legislation: CPR-Regulation (EU) No 305/2011 of the European Parliament and of the European Council.

AVCP (Assessment and Verification of Constancy of Performance): System 3

Notified body: EZÚ - Elektrotechnický zkušební ústav, s.p.
Pod Lisem 129/2, 182 00, Prague 8-Troja,
Czech Republic

Notified body No: 1014

Test report No: 260982-01/06

Declared performance and Harmonized standard

Essential Characteristic	Performance	Harmonized standard
Reaction to fire	Eca	According to EN50575:2014+A1:2016
Release of dangerous substances	NPD	NA

The performance of the product(s) identified above is in conformity with the set of declared performance/s. This declaration of performance is issued in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified below.

Product manager
Teodora Dimov



Date: 26.05.2026

Marketing manager
Aleksandra Bogoevska

